

CERTIFICATE

Certified Passive House Component


Component-ID 0503vs03 valid until 31st December 2016

Passive House Institute

Dr. Wolfgang Feist

64283 Darmstadt

Germany



Category: **Air handling unit with heat recovery**

Manufacturer: **Brink Climate Systems B.V.
Netherlands**

Product name: **Renovent Excellent 400 (Plus)**

Specification: Airflow rate < 600 m³/h

Heat exchanger: Recuperative

**This certificate was awarded based on the product
meeting the following main criteria**

Heat recovery rate HR 75 %

Specific electric power $P_{el,spec}$ 0.45 Wh/m³

Leakage < 3 %

Comfort Supply air temperature 16.5 °C
at outdoor air temperature -10 °C

Airflow range
77–290 m ³ /h
Heat recovery rate
84 %
Specific electric power
0.29 Wh/m ³



Brink Climate Systems B.V.

Wethouder Wassebaliestraat 8, 7951 -SN Staphorst, Netherlands

+31 522 46 99 44 | info@brinkclimatesystems.nl | http://www.brinkclimatesystems.nl |

Passive House comfort criterion

A minimum supply air temperature of 16.5 °C is maintained at an outdoor air temperature of -10 °C.

Efficiency criterion (heat recovery rate)

The effective heat recovery rate is measured at a test facility using balanced mass flows of the outdoor and exhaust air. The boundary conditions for the measurement are documented in the testing procedure.

$$HR = \frac{(\ E\!TA - \ E\!HA) \frac{P_{el}}{\dot{m} \cdot c_p}}{(\ E\!TA - \ O\!DA)}$$

With

- HR Heat recovery rate in %
- $E\!TA$ Extract air temperature in °C
- $E\!HA$ Exhaust air temperature in °C
- $O\!DA$ Outdoor air temperature in °C
- P_{el} Electric power in W
- \dot{m} Mass flow in kg/h
- c_p Specific heat capacity in Wh/(kg K)

Heat recovery rate

HR = 84 %

Efficiency criterion (electric power)

The overall electrical power consumption of the device is measured at the test facility at an external pressure of 100 Pa (50 Pa, respectively, for the intake and outlet). This includes the general electrical power consumption for operation and control but not for frost protection.

Specific electric power

$P_{el,spec}$ = 0.29 Wh/m³

Efficiency ratio

The efficiency ratio provides information about the overall energy performance of the respective ventilation unit. It specifies the achieved reduction in ventilation heat losses by using a ventilation unit with heat recovery rather than without.

Efficiency ratio

L = 0.65

Leakage

The leakage airflow must not exceed 3 % of the average airflow of the unit's operating range.

Internal leakage	External leakage
0.65 %	1.07 %

Settings and airflow balance

It must be possible to adjust the balance of airflows at the unit itself (either between the exhaust and the outdoor airflows or between the supply and the extract airflows, if the unit is respectively placed inside or outside of the insulated thermal envelope of the building).

This unit is certified for airflow rates of 77–290 m³/h.

Balancing the airflow rates of the unit is possible.

The user should have at least all the following setting options:

Switching the system on and off.

Synchronized adjustment of the supply and extract airflows to basic ventilation (70–80 %), standard ventilation (100 %) and increased ventilation (130 %) with a clear indication of the current setting.

The device has a standby power consumption of 2.30 W and therefore not complies with the target value of 1 W. The device should be equipped with an additional external switch so that it can be disconnected from the mains, if required.

After a power failure, the device will automatically resume operation.

Acoustical testing

The required limit for the sound power level of the device is 35 dB(A) in order to limit the sound pressure level in the installation room. The sound level target value of less than 25 dB(A) in living spaces and less than 30 dB(A) in functional spaces must be ensured by installing commercial silencers. The following sound power levels are met at an airflow rate of 290 m³/h:

Device	Duct			Exhaust air
	Outdoor	Supply air	Extract air	
51.5 dB(A)	52.4 dB(A)	49.7 dB(A)	47.0 dB(A)	61.6 dB(A)

The unit does not fulfil the requirements for the sound power level. The unit must therefore be installed acoustically separated from living areas.

One example of suitable silencers for supply and extract air ducts is mentioned in the detailed test report or can be obtained from the manufacturer. It is recommended to identify suitable silencers for each individual project.

Indoor air quality

This unit is equipped with following filter qualities by default:

Outdoor air filter	Extract air filter
G3	G3

On the outdoor air/ supply air side the filter quality class F7 is recommended. If not standard configuration, the F7 filter is available as accessory part.

Frost protection

Appropriate measures should be taken to prevent the heat exchanger and optional downstream hydraulic heater coil from getting damaged by frost during extreme winter temperatures (-15 °C). It must be ensured that the unit's ventilation performance is not affected during frost protection cycles.

Frost protection of the heat exchanger:

The apparatus is equipped with an integrated, electrical pre-heating element with an electrical power of about 1000 W. In order to fully utilise the full-range of the unit during cold winter months (down to -15 °C), an additional, external pre-heating element is demanded. The manufacturer recommends a preheating element of the type MQS 511335 rev. A, which has an electrical power of 1000 W.

Frost protection of downstream hydraulic heater coils:

In order to protect a downstream hydraulic supply air heater, an external thermostat must be installed. An undershooting of 5 °C supply air temperature must lead to a shutdown of the unit in order to protect a potential downstream hydraulic air heater.

