

TNO short report**TNO 2014 R10444****Performance of the energy
recovery appliance****“Renovent Sky150+”****Test report in accordance with NBN EN 308****Technical Sciences**Van Mourik Broekmanweg 6
2628 XE Delft
P.O. Box 49
2600 AA Delft
The Netherlandswww.tno.nl

T +31 88 866 30 00

F +31 88 866 30 10

infodesk@tno.nl

Date	10 March 2014
Author(s)	H.A.J. Hammink, B.Sc.
Copy no	0100005699
Number of pages	12 (incl. appendices)
Number of appendices	-
Sponsor	Brink Climate Systems BV R.D. Bügelstraat 3 7951 DA Staphorst
Project number	060.05366

All rights reserved.

No part of this publication may be reproduced and/or published by print, photoprint, microfilm or any other means without the previous written consent of TNO.

In case this report was drafted on instructions, the rights and obligations of contracting parties are subject to either the General Terms and Conditions for commissions to TNO, or the relevant agreement concluded between the contracting parties. Submitting the report for inspection to parties who have a direct interest is permitted.

© 2014 TNO

4 Summary of the test results

Efficiency of heat recovery

The heat recovery efficiency for the EPB are shown in table 8.

Table 8 Overview of heat recovery efficiencies for the EPB.

Nominal airflow	[m ³ /h]	150
qv,epb	[m ³ /h]	150.7
$\eta_{t,epb}$	[%]	77.6
Input $\eta_{t,epb}$	[%]	78.0